

**From:** [Brett O'Bray](#)  
**To:** [Jennifer Patton](#)  
**Subject:** RE: Fire Station One Periodic Monitoring January 2017  
**Date:** Tuesday, February 07, 2017 9:43:03 AM  
**Attachments:** [image001.jpg](#)  
[City of Valdez Fire Station One Mold Report 01-12-17.pdf](#)

---

Good morning Jennifer I apologize for the typo. Sample numbers 007 and 008 were found to respectively have spore counts of 160 and 110 spores per cubic meter. These are results that are background levels that are just above the limit of detection. These sample results are not indicative of current fungal amplification, are ubiquitous, and typically are found in most residences and commercial structures. No moisture indicating spores were detected in sample results. Indoor air quality is incredibly clean, and suitable for occupancy. I have amended the table and attached it for your review. I hope you enjoy the rest of your week.

Thank you for your business.

Brett O'Bray-CMC  
Vice President  
White Environmental Consultants Inc.  
Office 907-258-8661  
Mobile 907-748-2733  
WEC Logo



---

**From:** Jennifer Patton [mailto:jpatton@ci.valdez.ak.us]  
**Sent:** Tuesday, February 7, 2017 8:04 AM  
**To:** Brett O'Bray <Obray@wecenv.com>  
**Subject:** FW: Fire Station One Periodic Monitoring January 2017

Good Morning Brett,

Please see the comments below from Jason.

Thank you,

**Jennifer Patton**

Project Manager, Capital Facilities Dept.  
City of Valdez  
PO Box 307

Pioneer Field Ste. 201  
Valdez, AK 99686  
Ph: 907-835-5478  
Cell: 404-272-3804  
Fx: 907-835-5574  
[jpatton@ci.valdez.ak.us](mailto:jpatton@ci.valdez.ak.us)

---

**From:** Jason Miles  
**Sent:** Monday, February 06, 2017 5:51 PM  
**To:** Jennifer Patton  
**Subject:** RE: Fire Station One Periodic Monitoring January 2017

Jennifer,  
Please ask why the report does not match the lab results in one instance. Sample #7 should be 160 in the report, it appears, to match the lab result - not <53 as stated in the report. Also, are those two samples indicative of a problem? I don't know if we are to assume that these two results above 53 are still acceptable. His e-mail and report indicate there are no issues, I believe, but please have him confirm that with regard to these two particular test results that are above 53. Thanks.

Jason

---

**From:** Jennifer Patton  
**Sent:** Monday, February 06, 2017 4:40 PM  
**To:** Jason Miles  
**Subject:** FW: Fire Station One Periodic Monitoring January 2017

Here are the mold samples results for the fire station first quarter 2017.

## Jennifer Patton

Project Manager, Capital Facilities Dept.  
City of Valdez  
PO Box 307  
Pioneer Field Ste. 201  
Valdez, AK 99686  
Ph: 907-835-5478  
Cell: 404-272-3804  
Fx: 907-835-5574  
[jpatton@ci.valdez.ak.us](mailto:jpatton@ci.valdez.ak.us)

---

**From:** Brett O Bray [<mailto:Obray@wecenv.com>]  
**Sent:** Monday, February 06, 2017 3:17 PM  
**To:** Jennifer Patton  
**Subject:** Fire Station One Periodic Monitoring January 2017

Here you are, all good at the station this quarter, hope you had a great super bowl weekend.

Respectfully

Brett O'Bray-CMC

Vice President

White Environmental Consultants Inc.

Office 907-258-8661

Mobile 907-748-2733

WEC Logo

